

Bull Shoals wastewater monthly report

December 2024

- Called out for a clogged sewer main on Westwood Court/AltaVista Drive
- We had to call out Mountain Home vac/jetter truck, because ours did not have the volume and pressure required.
- Filed out SSO for manhole overflow on Pace's Ferry Drive, due to the large release of water From Westwood Court/AltaVista Drive clog
- Rehung/fixed Faulty Heaters in filter building
- Used blower in drying bed #2, then washed down to prepare for sludge
- Winterized sewer polymer/sludge mixing valve and headworks.
- Winterized lift stations
- Virtual meeting with EPA WaterTA Engineering/ Eastern Research Group, Inc. (ERG) about obtaining funds for wastewater improvements.
- Continuing semiannual oil changes on all Lift stations
- General daily plant checks and maintenance
- General facilities housekeeping
- Continued locating and GPS'ing of Sewer Manholes to build a GNSS/GIS asset management program for city 's infrastructure
- Lift station inspections and general maintenance
- Maintenance of LS #6 bypass pump
- Take four-hour composite samples to send to Arkansas Test Labs
- Treated 7,277,000 gallons in November

Michael Salentine

Wastewater Supervisor