

City of Bull Shoals

P.O. Box 390 -706 C.S. Woods Blvd. – Bull Shoals, AR 72619

Email: waterclerk@cityofbullshoals.org – Website: www.cityofbullshoals.org

Phone: (870) 445-4775 – Fax: (870) 445-4948

April 16, 2024

Council Meeting Notes

WATER DEPARTMENT

One Calls

Normal- 21

Emergency- 0

Service Orders

New Installations- 11

Out- 10

Transfer From- 0

Transfer To- 0

Disconnect for Non-Payment- 3

Reconnect from Non-Pay- 1

Vacation Reconnect- 3 (BB, Pt. Return, Dan)

Vacation Disconnect- 0

Location- 1

New Water/Sewer Connection- 1

Alteration orders- 33

Leak Checks- 8

Lock off - 0

ERT Swaps- 1

ERT Swap with leak Sensor- 1

Meter Checks- 10

Meter Pulled/Swap- 4

Meter box Lid Check/replace- 0

Turn off- 0

Turn on - 0

Meter stop replacement- 0

Meter/Manhole Replace/Repair- 0

Valve/Hydrant replace/repair/- 0

Water Clerk Alterations (Mailing address change, or phone number)- 9

Miscellaneous Notes

I am currently still training a new water assistant. All parks are now open and off vacation service for the year. Damsite #22 spicket repair.

Thanks,
Roger Edkin/DH

BULL SHOALS WATER & SEWER

Service Order Summary

From 03/16/2024 To No Date

Key Word:

9:00:14 AM

Page

6 of

6

4/16/2024

S.O. Description	S.O. Type	Count	[Key Word]	Count	Comment
New Installation	I	11			
Out	O	10			
Vacation Reconnect	Z	3			
Disconnect for NonPmt	D	2			
Reconnect for NonPmt	R	1			
Alteration	A	33			
Location	L	1			

City of Bull Shoals

P.O. Box 390 -706 C.S. Woods Blvd. – Bull Shoals, AR 72619

Email: waterclerk@cityofbullshoals.org – Website: www.cityofbullshoals.org

Phone: (870) 445-4775 – Fax: (870) 445-4948

Council Meeting Notes

April 16, 2024

ANIMAL CONTROL

Dogs in house

0

Call Outs

7

Pick ups

1

Adopted/Rehomed/Fostering/Found owner

1

Taken to another shelter

0

Taken to Vet

0

Animal rights relinquished

0

Water work

Sewer work

Street work

Helped in mowing around the City, helped with recycling, ran service orders, replaced light bulbs at City Hall. Replaced flags for street poles. Cleaned up limbs around city.

Miscellaneous Notes

Animal Control Officer exam is completed and passed. I am currently waiting to be sworn in.

Thanks,
Phil Lukes /DH

City of Bull Shoals

P.O. Box 390 -706 C.S. Woods Blvd. – Bull Shoals, AR 72619

Email: waterclerk@cityofbullshoals.org – Website: www.cityofbullshoals.org

Phone: (870) 445-4775 – Fax: (870) 445-4948

Council Meeting Notes

April 16, 2024

STREET DEPARTMENT

- Replaced some flags for street poles
- Pot holes filled on Mockingbird, Red Bud, Honeysuckle, Woodland, and other spots in town
- Brought in another load of cold mix from White River Materials
- City lots have been mowed
- Limbs cleaned up on Mockingbird
- Maintenance on Mahindra tractor and John Deere
- Leaves cleaned up at all parks and campgrounds, and they have all been mowed
- Received two new Hustler mowers
- Replaced skylight at bathroom in Point Return
- Replaced door closures at Danhouser Park bathroom
- Replaced shelf at Browns Beach Pavilion
- Painted parking stops and steps in Point Return safety yellow
- Filled in gravel in toad at Danhouser
- Volleyball court has been cleaned out.

RECYCLING

21 bales of cardboard
4 paper
13 clear
4 milk
5 bales of cans take to recycle center
1 colored plastic

1 baler inoperable

Miscellaneous Notes

Thanks,
Glenn Foster/DH

Bull Shoals wastewater monthly report

April 2024

- General daily plant checks and maintenance
- General facilities housekeeping
- Continued inspections and GPS locating of manholes
- Replaced both air release valves in LS2
- Replaced air release valve on #2 pump at LS 15
- Continued changing oil in Lift Station pumps
- Lift station inspections and general maintenance
- 3/25/2004 Damage assessment after storm to all lift stations and wastewater treatment facility report SSO on manhole at Rivercliff Creek daily total .954 MGD. Approximately 6.5 x our daily flow.
- Processed 4 drying beds of biosolids
- Take four-hour composite samples to send to Arkansas Test Labs
- Treated 6,320,000 gallons in March

James Jamieson
Wastewater Supervisor