

# Bull Shoals wastewater monthly report

## October 2024

- Unloaded both drying beds
- 20 Cubic feet of biosolids hauled to landfill
- Drained, cleaned and inspected clarifier #1
- Replaced missing bolt from sludge sweeper arms and adjusted tension on arms
- Started semiannual oil changes on all Lift stations
- Cleaned and filled drying bed #1
- Called ARWA to get on list to smoke test sewer mains
- Located sewer tap for new residence on Lynette Ave.
- General daily plant checks and maintenance
- General facilities housekeeping
- Continued locating and GPS'ing of Sewer Manholes to build a GNSS/GIS asset management program for city 's infrastructure
- Lift station inspections and general maintenance
- Maintenance of LS #6 bypass pump
- Take four-hour composite samples to send to Arkansas Test Labs
- Treated 4,170,000 gallons in September

Michael Salentine  
Wastewater Supervisor