

Bull Shoals wastewater monthly report

August 2024

- General daily plant checks and maintenance
- Removed and replaced bank #1 UV disinfection bulbs
- General facilities housekeeping
- Continued locating and GPS'ing of Sewer Manholes to build a GNSS/GIS asset management program for city 's infrastructure
- Repair micro screen on headworks damage to auger and washdown system
- Repair broken water lines on headworks
- Complete the stump removal on Sandot
- Lift station inspections and general maintenance
- Remove existing culverts and replace with a 36" culvert at LS 18
- Remove tree and repair fencing around LS 10
- Maintenance of LS #6 bypass pump
- Processed 2 drying beds of biosolids
- Take four-hour composite samples to send to Arkansas Test Labs
- Treated 6,977,000 gallons in July

James Jamieson
Wastewater Supervisor