

Bull Shoals wastewater monthly report

September 2024

- General daily plant checks and maintenance
- Replaced front brakes and front driver side brake rotor on the Ford F350
- Located sewer for new construction on Highland Drive
- Ditch Witch called out to do full service on vac trailer
- Zimdahl electric installed 250A meter loop and disconnect for lift station #6 upgrade.
- Coordinating with Entergy to get new electric lines and transformers installed.
- Put sludge to drying beds (Approx. 25,000 gallons)
- General facilities housekeeping
- Replaced rotating assembly on pump #1 in Lift Stion #2
- Continued locating and GPS'ing of Sewer Manholes to build a GNSS/GIS asset management program for city 's infrastructure
- Lift station inspections and general maintenance
- Maintenance of LS #6 bypass pump
- Take four-hour composite samples to send to Arkansas Test Labs
- Treated 4,525,000 gallons in August

Michael Salentine
Wastewater Supervisor