

City of Bull Shoals

P.O. Box 390 -706 C.S. Woods Blvd. – Bull Shoals, AR 72619

Email: waterclerk@cityofbullshoals.org – Website: www.cityofbullshoals.org

Phone: (870) 445-4775 – Fax: (870) 445-4948

November 21, 2023

Council Meeting Notes

STREET DEPARTMENT

- Finished brush pickup
- Installed steering cylinder on forklift
- Straighten street signs on 178
- Repaired oil leak by replacing hose on backhoe
- Cleaned out culvert on Margarets Lane with backhoe
- Put in gravel/sand mix on Locust so we can pave
- Paved road between hair salon and VFW
- Fixed tranny fluid leak on C-700 dump truck
- Filled potholes throughout town

RECYCLING

- 10 bales of cardboard
- 4 paper
- 8 clear
- 3 milk
- 1 can

Thanks,
Ed Martin/DH

City of Bull Shoals

P.O. Box 390 -706 C.S. Woods Blvd. – Bull Shoals, AR 72619

Email: waterclerk@cityofbullshoals.org – Website: www.cityofbullshoals.org

Phone: (870) 445-4775 – Fax: (870) 445-4948

November 21, 2023

Council Meeting Notes

WATER DEPARTMENT

One Calls

Normal- 10

Emergency- 0

Service Orders

New Installations-	7
Out-	9
Transfer From-	0
Transfer To-	0
Disconnect for Non-Payment-	4
Reconnect from Non-Pay-	0
Vacation Reconnect-	0
Vacation Disconnect-	4 (Parks)
Location-	1
New Water/Sewer Connection-	0

Alteration orders- 44

Leak Checks-	5
Lock off -	0
ERT Swaps-	6
ERT Swap with leak Sensor-	0
Meter Checks-	1
Meter Pulled/Swap-	5
Meter box Check/replace-	2
Turn off-	0
Turn on -	0
Meter stop replacement-	0
Meter/Manhole Replace/Repair-	0
Valve/Hydrant replace/repair/-	1
Water Clerk Alterations (Mailing address change, or phone number)-	20

Miscellaneous Notes

All parks are now on vacation service for the year. Replaces a valve at Point Return, working on bids for water tower painting and restoral.

Thanks,

Roger Edkin/DH

BULL SHOALS WATER & SEWER
Service Order Summary
From 10/17/2023 To 11/21/2023
Key Word:

9:10:36 AM

Page 7 of 7

11/21/2023

S.O. Description	S.O. Type	Count	[Key Word]	Count	Comment
New Installation	I	7			
Out	O	9			
Vacation Disconnect	V	4			
Disconnect for NonPmt	D	4			
Alteration	A	44			
Location	L	1			

City of Bull Shoals

P.O. Box 390 -706 C.S. Woods Blvd. – Bull Shoals, AR 72619

Email: waterclerk@cityofbullshoals.org – Website: www.cityofbullshoals.org

Phone: (870) 445-4775 – Fax: (870) 445-4948

November 21, 2023

Council Meeting Notes

ANIMAL CONTROL

Dogs in house

0

Call Outs

11

Pick ups

4

Adopted/Rehomed

0

Taken to another shelter

1

Animals rights relinquished

0

Miscellaneous Notes

I am currently set for final certification as Animal Control Officer. I am also working in water/sewer daily where needed.

Thanks,
Phil Lukes /DH

Bull Shoals wastewater monthly report

- Jetter called out to the end of Lake Street for manhole over flow
- Cleaned up overflow at end of Lake Street and Filed SSO with ADEQ
- Collected water samples from lake for ADEQ/ADH/OEM to check for E. coli, samples came back negative.
- Fence company called out to repair fence after tree came down on North side of sewer plant
- Replaced torn panels in disc filter
- General maintenance of lift stations and sewer plant
- Take four-hour composite samples to send to Arkansas Test Labs
- Treated 4,679,000 gallons in October

Thank You,

Micheal Salentine
Wastewater Supervisor