

City of Bull Shoals

P.O. Box 390 -706 C.S. Woods Blvd. – Bull Shoals, AR 72619

Email: waterclerk@cityofbullshoals.org – Website: www.cityofbullshoals.org

Phone: (870) 445-4775 – Fax: (870) 445-4948

February 14, 2023

Council Meeting Notes

WATER DEPARTMENT

One Calls

Normal- 9

Emergency-2

Service Orders

New Installations-	4
Out-	7
Transfer From-	0
Transfer To-	0
Disconnect for Non-Payment-	0
Reconnect from Non-Pay-	0
Vacation Reconnect-	0
Vacation Disconnect-	0
Location-	1
New Water/Sewer Connection-	2

Alteration orders- 32

Leak Checks-	12
Lock off -	0
ERT Swaps-	0
ERT Swap with leak Sensor-	0
Meter Checks-	3
Meter Pulled-	1
Meter box Check-	0
Turn off-	1 (customer went to sewer only)
Turn on -	0
Meter stop replacement-	0
Meter Lid Replace/Repair-	0
Water Clerk Alterations (Mailing address change, or phone number)-	15

Miscellaneous Notes

Lots of customer water leaks due to the weather. (Pipes froze and busted)

Thanks,

Roger Edkin/DH

BULL SHOALS WATER & SEWER
Service Order Summary
From 01/17/2023 To No Date
Key Word:

12:20:22 PM

Page 5 of 5

2/14/2023

S.O. Description	S.O. Type	Count	[Key Word]	Count	Comment
New Installation	I	4			
Out	O	7			
Alteration	A	32			
Location	L	1			

Street department 2-14-23

- **culvert and ditch clean out around city**
- **continuing shop ,and facilities clean up and maintenance**
- **pot holes filled on eastern, mockingbird
redbud, shorecrest, kingsway**
- **One mower sent out for repair**
- **Repair dogwood st**
- **Removed plows and spreader**
- **Removed trees and limbs from storm damage**
-

- **Animal control
One dog in house!**

Recycling

2 bales of cardboard

1 bale clear plastic

One baler inoperable

Bull Shoals wastewater monthly report

- Replaced backwash nozzles on disc filter
- Reported manhole overflow at the triangle on Golf Course Terrace and Rivercliff to ADEQ.
- Clean up and disinfected and deodorized manhole overflow
- Cleaned and washed out drying both beds
- Ordered U.V bulbs and quartz sleeves for the disinfection system
- Ordered pump for lift station on Falltime Drive.
- General maintenance of lift stations and sewer plant
- Take four-hour composite samples to send to Arkansas Test Labs
- Treated 4,914,000 gallons in January

Thank You,

Micheal Salentine

(Any Questions call me @ 1(870)421-0842)