

Bull Shoals wastewater monthly report

- General daily plant checks and maintenance
- Training of new employees
- General facilities housekeeping
- Solids handling dispose of 20 cubic yds of solids
- Solids handling load drying beds 4x
- Lift station inspections and general maintenance
- Ls 16 Sensor Failure work with Jack Tylor Eng. To resolve problem.
- Replace impellor stack on disc filter pump and returned unit to service
- Resolve sewer back up 134 Sandot with the assistance of the City of Mountain Home
- Damage assessment after storm to all lift stations and wastewater treatment facility
- Take four-hour composite samples to send to Arkansas Test Labs
- Treated 4,866,000 gallons in January

James Jamieson/Micheal Salentine
Wastewater Supervisor