

City of Bull Shoals

P.O. Box 390 -706 C.S. Woods Blvd. – Bull Shoals, AR 72619

Email: waterclerk@cityofbullshoals.org – Website: www.cityofbullshoals.org

Phone: (870) 445-4775 – Fax: (870) 445-4948

July 18, 2023

Council Meeting Notes

STREET DEPARTMENT

Cleared McDonald Meadows and Summit of low hanging brush.

Received work order on water crossing road on Cardinal, found buried culvert was totally blocked-Cleared

Put in a one call for Walden Lane.

Had a fallen tree blocking road by cemetery-cut and hauled away.

Tried to reset the post and wire on Rivercliff due to vehicle running through it.

Cut down tree hanging over Overhill Road.

Took John Deere tractor and cleared alleyway behind hardware store building.

Had people laying asphalt for dentist office to spread the extra/leftover on Springdale and Allendale.

WORKING ON AT PRESENT TIME

Brush hogging

Cleaning culverts

Clearing blocked street of trees/limbs since storm

ANIMAL CONTROL

0 at this time

RECYCLING

0 bales of cardboard

4 paper

5 clear

2 milk

1 baler inoperable

Thanks,
Ed Martin/DH

City of Bull Shoals

P.O. Box 390 -706 C.S. Woods Blvd. – Bull Shoals, AR 72619

Email: waterclerk@cityofbullshoals.org – Website: www.cityofbullshoals.org

Phone: (870) 445-4775 – Fax: (870) 445-4948

July 18, 2023

Council Meeting Notes

WATER DEPARTMENT

One Calls

Normal- 15

Emergency- 2

Service Orders

New Installations- 6

Out- 4

Transfer From- 0

Transfer To- 0

Disconnect for Non-Payment- 0

Reconnect from Non-Pay- 0

Vacation Reconnect- 0

Vacation Disconnect- 0

Location- 1

New Water/Sewer Connection- 2

Alteration orders- 31

Leak Checks- 2

Lock off - 0

ERT Swaps- 3

ERT Swap with leak Sensor- 0

Meter Checks- 3

Meter Pulled/Swap- 0

Meter box Check- 0

Turn off- 3

Turn on - 2

Meter stop replacement- 0

Meter/Manhole Replace/Repair- 2

Valve replacement/repair/check-1

Water Clerk Alterations (Mailing address change, or phone number)-15

Miscellaneous Notes

Worked to big water leaks in town

Thanks,

Roger Edkin/DH

BULL SHOALS WATER & SEWER

Service Order Summary

From 06/18/2023 To No Date

Key Word:

9:28:16 AM

Page 6 of 6

7/18/2023

S.O. Description	S.O. Type	Count	[Key Word]	Count	Comment
New Installation	I	6			
Out	O	4			
Alteration	A	31			
Location	L	1			

Bull Shoals wastewater monthly report

- Filled both Drying beds
- Two vac trailer call out for water leaks
 - Kingswood Cir.
 - Walnut Ave
- Drained and cleaned clarifier #2
- Cooper Industries called to troubleshoot lift station #6
- Sewer locate on Blou Clower Pt.
- Sewer call out on Morning Glory Dr., removed roots infiltrating into manhole.
- General maintenance of lift stations and sewer plant
- Take four-hour composite samples to send to Arkansas Test Labs
- Treated 4,217,000 gallons in June

Thank You,

Micheal Salentine
Wastewater Supervisor